

PRIMRYHEALTH CENTRE, NAGAROOOR

PHONE NO. 0470-2678656 E-mail:phcnagaroor@gmail.com

ALTHARAMOODUTHIRUVANANTHAPURAM

No.16/71/2026/PHCN

Dated: 24.03.2026

SANITATION CERTIFICATE

This is to be certified that the premises and sanitary condition including waste management facility provided at building no:XVII/529 Nagaroor Grama Panchayath, ALPHA PUBLIC SCHOOL at Peroor is found satisfactory during inspection conducted by me on 12.03.26. Therefore, this Sanitary Certificate is issued for the Academic year 2026-27 for CBSE Affiliation

This certificate is purely temporary and the inspecting Authority has every right to cancel the issued certificate, if the institution was found functioning in unhygienic condition or feel functioning as threat to Public Health.

Nagaroor,
24.03.26



fbchith82
HEALTH INSPECTOR,
PRIMARY HEALTH CENTRE,
NAGAROOOR

HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
NAGAROOOR



WATER QUALITY TEST REPORT

Test Report No: MSK/PMMSY//TVM-26/355

Date: 23/03/2026

Name: Alpha Public School, Perorr P.O, Kilimanoor Ph: 9846533991 SAMPLE TYPE : Bore Well Water	Sample received on: 21/03/2026 Analysis date : 21/03/2026 Sampling done by : Customer Sample quantity : 1L
---	---

Sl.No.	PARAMETERS	RESULT	ACCEPTABLE LIMIT AS PER IS 10500 - 2012	TEST METHOD
PHYSICAL AND CHEMICAL PARAMETERS				
1	Apparent Colour	Colourless	Colourless	ISO 7887: 2011
2	Odour	Agreeable	Agreeable	IS 3025 Part 5
3	Turbidity	0.02NTU	1 NTU (Max)	IS 3025(Part 10)
4	pH	6.51	6.5 – 8.5	IS 3025(Part 11) 2022
5	Alkalinity	20mg/l	200mg/l	IS 3025(Part 23) 2022
6	Conductivity	248.4µs	-	IS 3025(Part 14) 2013
7	Total Dissolved Solids	238.4ppm	500ppm (Max)	IS 3025(Part 16) 2022
8	Total Hardness	62.01mg/l	200mg/l (Max)	IS 3025 (Part 21)
9	Calcium Hardness	47.42mg/l	75mg/l (Max)	IS 3025 (Part 40)
10	Magnesium Hardness	14.59mg/l	30mg/l (Max)	IS 3025 (Part 46)
11	Chloride	24.50mg/l	250mg/l	IS 3025(Part 32)
12	Residual Chlorine	ND	0.2mg/l	IS 3025(Part 26)
13	Nitrate	Less than 5ppm	45ppm	IS 3025 (Part34)
14	Fluoride	ND	1mg/l	IS 3025 (Part 60)
15	Iron	BDL	0.3mg/l	IS 3025 (Part53)
16	Sulphate	7.86mg/l	200mg/l	IS 3025(Part 24)

BACTERIOLOGY				
Sl.No.	PARAMETERS	RESULT	ACCEPTABLE LIMIT AS PER IS 10500 -2012	TEST METHOD
17	Total Coliforms	Absent	Shall not be present in 100ml	IS 15185: 2016
18	<i>E.coli</i>	Absent	Shall not be present in 100ml	IS 15185: 2016

BDL= Below Detection Limit; DL=Detection Limit; ND= Not Detected; CFU=Colony Forming Units
REMARKS: "The above water sample conforms to IS: 10500:2012 drinking water specification with respect to above tested parameters".

NB: The above stated results shall be related only to the sample submitted for testing. This report shall not be reproduced except in full without the approval of the laboratory.

END OF THE REPORT

Report Verified By

Dr. Pramitha V. S., Fisheries Expert, Matsya Seva Kendra (PMMSY), TVM

